

**FORMAL SITE PLAN REVIEW MEETING**  
**Regulatory Services**  
**Building Division**

**Scheduled for April 2, 2015**  
**9:00 a.m. – 2<sup>nd</sup> Floor Hearing Room**  
**367 Main Street, Hyannis, MA**

**NEW APPLICATIONS:**

**SPR 008-15**            **Cotuit Fire District Water Department**  
**9 West Street, Cotuit**  
**Map 021, Parcel 009**  
**Zoning District: RF, WP Overlay, RPOD**

**Proposal:**            **Replacement of an existing 200,000 gallon elevated water storage tank with a 300,000 gallon pedishere-style elevated water storage tank. New tank will provide adequate storage for population needs for the year 2020 and an increase in necessary fire flows.**